

**Exam** : **EUCOC**

**Title** : Intermediate Certificate in  
EU Code of Conduct for  
Data centres

**Version** : Demo

1. Why has the EU Code of Conduct on Data Centres been developed?

- a. Because data centres are using an increasing amount of power and they need to maximise their efficiency to reduce their impact on the power infrastructure.
- b. Because the power consumption of data centres across Europe as a whole needs to fall to meet agreed CO2 targets.
- c. Because many data centres have outdated designs which focus on perceived reliability at the expense of cost and energy efficiency.
- d. Because the energy consumption of data centres has become a significant business cost.
- e. Because the United States (US) has taken a significant lead in energy conservation and EU-based data centres need a code of conduct to compete in a global marketplace.

A. a, b, c and d

B. a, c and d

C. b and e

D. e only

**Answer: B**

2. Which of the following BEST define the aims of the EU Code of Conduct on Data Centres.?

- a. To determine and accelerate the application of energy efficient technologies.
- b. Develop practical voluntary commitments which when implemented improve the energy efficiency of data centres and in so doing minimise the Total Cost of Ownership (TCO).
- c. To develop and promote a set of easily understood metrics to measure the current efficiencies and subsequent improvement.
- d. To encourage the closure of data centres that are less energy efficient.
- e. To ensure that the EU is visibly taking a lead in this important area of energy conservation.

A. a, b, c and d

B. d and e

C. a, b and c

D. e only

**Answer: C**

3. A facility's 'IT load', as defined by the Code of Conduct, includes the power drawn by which of the following?

- a. The Power Distribution Units feeding the racks
- b. Servers
- c. Firewalls
- d. Switches
- e. Tape libraries

A. b, c, d and e

B. a, d and e

C. b and c

D. b, c and d

**Answer: A**

4. 'Facility load', as defined by the Code of Conduct, includes the power drawn by which of the following?

- a. The UPS.
- b. Lighting.
- c. Air-conditioning units.
- d. Monitors housed in racks.
- e. Tape libraries

A. a, b, and c

B. a and d

C. b and c

D. d, and e

**Answer: A**

5. The numerical value associated with each Best Practice is shown for the following reason:

A. To allow operators to add up their total score in order that they can be compared with their competitors.

B. To allow the Code of Conduct administrators to properly assess each application.

C. To provide an independent scorecard for data centre owners.

D. To indicate the level of benefit from carrying out a Best Practice.

**Answer: D**

# Trying our product !

- ★ **100%** Guaranteed Success
- ★ **100%** Money Back Guarantee
- ★ **365 Days** Free Update
- ★ **Instant Download** After Purchase
- ★ **24x7** Customer Support
- ★ Average **99.9%** Success Rate
- ★ More than **69,000** Satisfied Customers Worldwide
- ★ Multi-Platform capabilities - **Windows, Mac, Android, iPhone, iPod, iPad, Kindle**

## Need Help

Please provide as much detail as possible so we can best assist you.

To update a previously submitted ticket:



 <b>One Year Free Update</b> <p>Free update is available within One Year after your purchase. After One Year, you will get 50% discounts for updating. And we are proud to boast a 24/7 efficient Customer Support system via Email.</p>	 <b>Money Back Guarantee</b> <p>To ensure that you are spending on quality products, we provide 100% money back guarantee for 30 days from the date of purchase.</p>	 <b>Security &amp; Privacy</b> <p>We respect customer privacy. We use McAfee's security service to provide you with utmost security for your personal information &amp; peace of mind.</p>
---	---	--

## Guarantee & Policy | Privacy & Policy | Terms & Conditions

Any charges made through this site will appear as Global Simulators Limited.

All trademarks are the property of their respective owners.

Copyright © 2004-2014, All Rights Reserved.